



**Nuplex Construction**  
**Report No. NU 1310-671**

# Cleanroom<sup>®</sup> Suitable Materials

**Sureshield**  
**Microbicidity: very good**

## Flooring & Coating

### Qualification Certificate

We hereby certify that the material stated above, provided by

**Nuplex Construction Products**  
Christchurch, New Zealand

has been awarded the Fraunhofer IPA CSM Certificate of Qualification with the report number NU 1310-671.

Sureshield (Natural Gold; PR307706) was tested in accordance with CSM procedures of biological resistance. The tested material obtained the following classification.

Classification	Reduction factor R	CSM
<i>S. aureus</i>	> 3.3	very good
<i>E. coli</i>	> 5.4	excellent
<b>Overall Result</b>	<b>&gt; 3.3</b>	<b>very good</b>

Detailed information regarding specific product data such as date of manufacture, color, and serial number as well as test environment and parameters can be obtained from the CSM test report issued by the Fraunhofer-Gesellschaft.

Stuttgart, December 12, 2013

F.A.   
Project manager

The validity of this certificate is temporary indefinite and limited to the named product. It can be verified on [www.tested-device.com](http://www.tested-device.com).

For more CSM information, please visit [www.ipa-csm.com](http://www.ipa-csm.com).